



Grandeco Wallfashion Group Belgium nv
Wakkensteenweg 49
B-8700 Tielt

Your message - reference

-

our reference

PW/2769

Gent

2021-10-12

Certification report 21/2769

1. Description of the wall covering:

Product family	Decorative vinyl wall covering on nonwoven or paper backings
Total mass	165-290 g/m ²

2. Test executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified according EN13501-1 as follows:

C – s2, d0

field of application: glued (methyl cellulose glue applied at the rate of 250 gr/m²) on end-use substrates having a Euroclass A2-s1,d0 or A1 which density is superior to 652,2 kg/m³ (except plasterboard).

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 7 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB

addressee	our reference	Gent	page
Grandeco Wallfashion Group Belgium	PW/2769	2021-10-12	2

Related commercial names to this product group	DOP-CPR-1 DOP-CPR-2 DOP-CPR-3 DOP-CPR-4
The obtained classification is based on the next test reports	Crepim DO-21-2831_H-R1 dated 19-05-2021 Crepim DO-21-2831_F-R1 dated 19-05-2021 Crepim DO-21-3001_A-R1 dated 16-06-2021 Crepim DO-21-3001_B-R1 dated 16-06-2021 Crepim DO-21-3151_A-R1 dated 12-08-2021 Crepim DO-21-3151_B-R1 dated 12-08-2021 Crepim DO-21-3151_C-R1 dated 12-08-2021
Validity of the certificate	18-05-2026

Petra Wittevrongel

Product Certifier

